


# Overview for washer januari 2020

95% Chemical washer

Scores last year:



Total score:

# 5

Januari 2020


pH




Conductivity



Pump operating hours




Reieved measurements




## Details:

<b>Reieved measurements</b>	93,1% (693 where 744 expected)
<b>Valid pH:</b>	99,7% of the time within margin (<= 3)
<b>Valid conductivity:</b>	100,0% of the time within margin (<= 250)
<b>Valid pressure drop master:</b>	100,0% of the time within margin (<= 65)
<b>Pump operating hours:</b>	99,0% of the time
<b>Power usage</b>	832 kWh (23.059,1 kWh total)
<b>Water usage</b>	1,6 m3 (351,3 m3 total)
<b>Waste water</b>	0,2 m3 (57,9 m3 total)


pH



Conductivity



Pump operating hours



Reieved measurements

