


Overview for washer januari 2020

95% Chemical washer with 1 slave washer



Scores last year:



Total score:

9


Januari 2020




Details:

Recieved measurements	97,0% (722 where 744 expected)
Valid pH:	98,1% of the time within margin (<= 3)
Valid conductivity:	99,9% of the time within margin (<= 250)
Valid pressure drop master:	99,9% of the time within margin (<= 65)
Valid pressure drop slave 1:	99,7% of the time within margin (<= 65)
Pump operating hours:	98,5% of the time
Power usage	639 kWh (58.577,3 kWh total)
Water usage	6,0 m3 (1.725,7 m3 total)
Waste water	3,3 m3 (384,0 m3 total)


pH



Conductivity



Pump operating hours



Recieved measurements

